

SECTION 238129 VARIABLE REFRIGERANT FLOW HVAC SYSTEM

PART 1 GENERAL

1.1 SECTION INCLUDES

A. Variable refrigerant volume HVAC system includes:

1. Outdoor/Condensing unit(s):
 - a. Size Range: 6 to 34 Tons Nominal
2. Indoor Unit(s)
 - a. Size Range: 1/2 to 5 Tons Nominal

1.2 SUBMITTALS

- a. Product Data: Include rated capacities, furnished specialties, and accessories for each model.
- b. Shop Drawings: Detail equipment assemblies and indicate dimensions, weights, loads, required clearances, method of field assembly, components, and location and size of each field connection.
 - 1) Wiring Diagrams: Power, signal, and control wiring.
- c. Coordination Drawings: Floor plans, reflected ceiling plans, and other details, drawn to scale, on which the following items are shown and coordinated with each other, based on input from installers of the items involved:
 - 1) Suspended ceiling components.
 - 2) Structural members to which heat pumps will be attached.
 - 3) Method of attaching hangers to building structure.
 - 4) Size and location of initial access modules for acoustical tile.
 - 5) Items penetrating finished ceiling, including the following:
 1. Lighting fixtures.
 2. Air outlets and inlets.
 3. Speakers.
 4. Sprinklers.
 5. Access panels.
- d. Samples for Initial Selection: For units with factory-applied color finishes.
- e. Samples for Verification: For each type of unit indicated.
- f. Product Certificates: For each type of water-source heat pump, signed by product manufacturer.
- g. Field quality-control test reports.

- h. Operation and Maintenance Data: For water-source heat pumps to include in emergency, operation, and maintenance manuals.

1.3 QUALITY ASSURANCE

- A. Product Options: Drawings indicate size, profiles, and dimensional requirements of water-source heat pumps and are based on the specific system indicated. Refer to Division 1 Section "Product Requirements."
- B. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.
- C. Comply with ASHRAE 15.
- D. Comply with minimum COP/EER efficiency levels according to ASHRAE/IESNA 90.1-2019.
- E. Comply with NFPA 70.
- F. Comply with ARI/ISO/ASHRAE 13256-1 for 'Water Loop' application.
- G. Comply with safety requirements in UL 484 for assembly of free-delivery water-source heat pumps.
- H. Comply with safety requirements in UL 1995 for duct-system connections
- I. The units shall be tested by a Nationally Recognized Testing Laboratory (NRTL), in accordance with ANSI/UL 1995/CAN/CSA-C22.2 No. 236-05 (R2009) – Heating and Cooling Equipment and bear the Listed Mark.
- J. The system will be produced in an ISO 9001 and ISO 14001 facility, which are standards set by the International Standard Organization (ISO). The system shall be factory tested for safety and function.
- K. The outdoor unit will be factory charged with R-410A.

1.4 COORDINATION

- A. Coordinate layout and installation of water-source heat pumps and suspension components with other construction that penetrates ceilings or is supported by them, including light fixtures, HVAC equipment, fire-suppression system components, and partition assemblies.
Coordinate layout and installation of water-source heat pumps and suspension components with other construction that penetrates ceilings or is supported by them, including light fixtures, HVAC equipment, fire-suppression system components, and partition assemblies.

1.5 WARRANTY

A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace components of water-source heat pumps that fail in materials or workmanship within specified warranty period.

1. Failures include, but are not limited to, refrigeration components.
2. Warranty Period:
 - a. Five (5) years from date of Substantial Completion.

B. Warranty Period Commencement: This period shall be upon written approval by Owner when recommended by Engineer. "Acceptance by Owner" is defined as written approval by the Owner that the equipment has been operating free from defects in manufacturer assembly and shipping. Warranty period will begin immediately after startup is "satisfactory" completed and units are running reliably, not when delivered or installed. "Satisfactory" completed is after air balancing, water balancing, and control interlocks are checked by the Engineer.

PART 2 PRODUCTS

2.1 MANUFACTURERS

A. DESIGN BASIS:

1. Daikin.
 - a. The HVAC equipment basis of design is Daikin North America. All bidders shall furnish the minimum system standards as defined by the base bid model numbers, model families or as otherwise specified herein. In any event, the contractor shall be responsible for all specified items and intents of this document without further compensation.

B. ALTERNATE BID INSTRUCTION

1. Mitsubishi Electric/Trane.
2. Toshiba/Carrier.
3. Johnson Controls-Hitachi/York.
4. LG.
 - a. Provide basis of design bid as specified. If the contractor proposes an alternate manufacturer for the basis of designed products, they shall provide a separate and complete Bid detailing the proposed alternate products and the associated adjustment of price to support the change from basis of design products. The contractor bids the alternate product with full knowledge that the proposed product may not be acceptable or approved. In no event shall the contractor be entitled to additional compensation to supply such specified products, options, or sequences. Any and all additional cost, to any party, because of any product submitted on or supplied other than that of the original specified products shall be the responsibility of the contractor without recourse. It is agreed that any and all disputes regarding

any differences between the specified products, options, or sequences and that proposed as an alternate shall be arbitrated by the engineer of record. It shall be further agreed by all parties that all decisions of arbitration shall be final and binding. Any product proposed as an alternate shall have been offered, as a VRF product, in the United States for a minimum of (5) years.

2.2 HVAC SYSTEM DESIGN

A. SYSTEM DESCRIPTION:

1. The variable capacity heat pump air conditioning system shall be a Daikin Variable Refrigerant Volume Series (heat or cool model) system as specified.
2. The system shall consist of multiple evaporators using PID control, REFNET™ joints and headers, a two-pipe refrigeration distribution system and Daikin VRV® condenser unit.
3. The condenser shall be a direct expansion (DX), air-cooled heat pump, multi-zone air-conditioning system with variable speed inverter driven compressors using R-410A refrigerant.
4. The condensing unit may connect an indoor evaporator capacity up to 200% of the condensing unit capacity. All zones are each capable of operating separately with individual temperature control.
5. The Daikin condensing unit shall be interconnected to indoor unit models FXFQ, FXHQ, FXUQ, FXEQ, FXMQ, FXLQ, FXNQ, FXTQ, FXDQ, FXZQ, FXAQ and FXMQ_MF, and shall range in capacity from 7,500 Btu/h to 96,000 Btu/h in accordance with Daikin’s engineering data book detailing each available indoor unit.
 - a. The indoor units shall be connected to the condensing unit utilizing Daikin’s REFNET™ specified piping joints and headers to ensure correct refrigerant flow and balancing. T style joints are not acceptable for a variable refrigerant system.
6. Operation of the system shall permit either cooling or heating of all of the indoor units simultaneously. Each indoor unit or group of indoor units shall be able to provide set temperature independently via a local remote controller, an Intelligent Manager, an Intelligent Controller or a BMS interface.
7. The RXYQ_TA condensing unit model numbers and the associated number of connectable indoor units per RXYQ_TA condensing unit is indicated in the following table. Each indoor unit or group of indoor units shall be independently controlled.

MODEL NUMBER	NOMINAL CAPACITY (Tons)	MAXIMUM NUMBER OF INDOOR UNITS
RXYQ72TAYD*	6	12
RXYQ96TAYD*	8	16
RXYQ120TAYD*	10	20
RXYQ240TAYD*	20	41

B. VRV IV FEATURES AND BENEFITS

1. Voltage Platform - Heat pump condensing units shall be available with a 460V/3ph/60Hz power supply.
2. Advanced Zoning - A single system shall provide for up to 64 zones.
3. Independent Control - Each indoor unit shall use a dedicated electronic expansion valve with 2000 positions for independent control.
4. VFD Inverter Control and Variable Refrigerant Temperature - Each condensing unit shall use high efficiency, variable speed all “inverter” compressor(s) coupled with inverter fan motors to optimize part load performance. The system capacity and refrigerant temperatures shall be modulated automatically to set suction and condensing pressures while varying the refrigerant volume for the needs of the cooling or heating loads. The control will be automatic and customizable depending on load and weather conditions.
 - a. Indoor shall use PID to control superheat to deliver a comfortable room temperature condition and optimize efficiency.
5. Configurator software - Each system shall be available with configurator software package to allow for remote configuration of operational settings and also for assessment of operational data and error codes.
 - a. If this software is not provided by an alternate manufacturer, for each individual outdoor unit the contractor shall do the settings manually and keep detailed records for future maintenance purposes.
6. Auto charging - Each system shall have a refrigerant auto-charging function.
7. Flexible Design –
 - a. Systems shall be capable of up to 540ft (165m) [623 ft. (190m) equivalent] of linear piping between the condensing unit and furthest located indoor unit.
 - b. Systems shall be capable of up to 3,280ft (1,000m) total “one-way” piping in the piping network.
 - c. Systems shall have a vertical (height) separation of up to 295ft (90m) between the condensing unit and the indoor units.
 - d. Systems shall be capable of up to 295ft from the first REFNET™ / branch point.
 - e. The condensing unit shall have the ability to connect an indoor unit evaporator capacity of up to 200% of the condensing unit nominal capacity.
 - f. Systems shall be capable of 98ft (30m) vertical separation between indoor units.
 - g. Condensing units shall be supported with a fan motor ESP up to 0.32” WG as standard to allow connection of discharge ductwork and to prevent discharge air short circuiting.
8. Oil Return – Each system shall be furnished with a centrifugal oil separator and active oil recovery cycle.
9. Simple wiring – Systems shall use 16/18 AWG, 2 wire, stranded, non-shielded and non-polarized daisy chain control wiring.
10. Space saving – Each system shall have a condensing unit module footprint no larger than 48-7/8” x 30-3/16” (1694mm x 1242mm x 767mm).

11. Advanced diagnostics – Systems shall include a self-diagnostic, auto-check function to detect a malfunction and display the type and location.
12. Each condensing unit shall incorporate contacts for electrical demand shedding with optional 3 stage demand control with 12 customizable demand settings.
13. Advanced controls – Each system shall have at least one remote controller capable of controlling up to 16 indoor units.
14. Each system shall be capable of integrating with open protocol BACnet and LonWorks building management systems.
15. Low sound levels - Each system shall use indoor and condensing units with quiet operation as low as 27 dB(A).

C. PERFORMANCE:

1. The VRV IV RXYQ_TA system shall perform as indicated below:

MODEL NUMBER	SYSTEM IEER (Ducted)	SYSTEM IEER (Non-Ducted)
RXYQ72TAYD*	20.7	25.9
RXYQ96TAYD*	22.7	28.0
RXYQ120TAYD*	21.4	23.5
RXYQ240TAYD*	18.4	20.8

MODEL NUMBER	SYSTEM EER (Ducted)	SYSTEM EER (Non-Ducted)
RXYQ72TAYD*	12.7	14.8
RXYQ96TAYD*	13.0	15.1
RXYQ120TAYD*	12.1	13.2
RXY240TAYD*	11.5	11.6

MODEL NUMBER	SYSTEM COP@47°F (Ducted)	SYSTEM COP@47°F (Non-Ducted)
RXYQ72TAYD*	3.30	3.89
RXYQ96TAYD*	4.0	4.6
RXYQ120TAYD*	3.5	3.8
RXYQ240TAYD*	3.6	3.6

MODEL NUMBER	SYSTEM COP@17°F (Ducted)	SYSTEM COP@17°F (Non-Ducted)
RXYQ72TAYD*	2.25	2.50
RXYQ96TAYD*	2.6	2.9
RXYQ120TAYD*	2.6	2.6
RXYQ240TAYD*	2.4	2.6

2. Performance Conditions:
 - a. Cooling: Indoor temperature of 80°FDB (26.7°CDB), 67°FWB (19.5°CWB) and outdoor temperature of 95°FDB (35°CDB).
 - b. Heating: Indoor temperature of 70°FDB (21.1°CDB) and outdoor temperature of 47°FDB (8.3°CDB), 43°FWB (6.1°CDB).
 - c. Equivalent piping length: 25ft (7.5m)

3. Cooling Operation:
 - a. The operating range in cooling will be 23°F DB ~ 122°F DB (-5°CDB ~ 50°CDB).
 - b. Cooling mode indoor room temperature range will be 57-77°FWB (13.8 - 25°CWB).
 - c. Cooling operation may be extended down to 10°F DB when the system is designed with the following limitations:
 - 1) The system must be a single module outdoor unit: RXYQ72/96/120/144/168TA.
 - 2) The smallest capacity indoor unit connected to the system must be 12,000 Btu/h.
 - 3) The system must run continuously in cooling operation with a minimum of 1.5 tons of indoor units in operation.

4. Heating Operation:
 - a. The operating range in heating will be -4°F WB – 60°F WB (-20°CWB – 15.5°CWB).
 - b. Heating mode indoor room temperature range will be 59°FDB - 80°F DB (15°CDB – 26.7°CDB).

2.3 EQUIPMENT

A. ELECTRICAL:

1. The power supply to the condensing unit shall be:

POWER SUPPLY VOLTAGE	VOLTAGE RANGE
280V / 3ph / 60 Hz	187V – 253V (±10%)

MODEL	MCA	MOP	COMPRESSOR RLA
RXYQ72TAYD*	27.6	35	15.7
RXYQ96TAYD*	36.3	45	23.8
RXYQ120TAYD*	36.3	45	26.2
RXYQ240TAYD*	36.3+36.3	45+45	26.2+26.2

B. WIRING:

1. The control voltage between the indoor and condensing unit shall be 16VDC non-shielded, stranded 2 conductor cable.

2. The control wiring shall be a two-wire multiplex transmission system, making it possible to connect multiple indoor units to one condensing unit with one 2-cable wire, thus simplifying the wiring installation.
3. The control wiring maximum lengths shall be as shown below:

	CONDENSER TO INDOOR UNIT	CONDENSER TO CENTRAL CONTROLLER	INDOOR UNIT TO REMOTE CONTROL
CONTROL WIRING LENGTH	6,560 ft (2,000 m)	3,280 ft (1,000 m)	1,640 ft (500 m)
WIRE TYPE	16/18 AWG, 2 wire, non-polarity, non-shielded, stranded		

C. REFRIGERANT PIPING:

1. The system shall be capable of refrigerant piping up to 540ft (165m) actual or 623ft (190m) equivalent from the condensing unit to the furthest indoor unit, a total combined liquid line length of 3,280ft (1,000m) of piping between the condensing and indoor units with 295ft (90m) maximum vertical difference, without any oil traps or additional components.
2. REFNET™ piping joints and headers shall be used to ensure proper refrigerant balance and flow for optimum system capacity and performance.
 - a. T style joints shall not be acceptable as this will negatively impact proper refrigerant balance and flow for optimum system capacity and performance.

D. PAINT/CORROSION RESISTANCE:

1. Paint and corrosion resistance shall be at a minimum per the table below:
- 2.

COMPONENT	VRV IV		
	BASE MATERIAL	SURFACE TREATMENT	COATING THICKNESS
			External & Internal Surface
EXTERNAL PANEL BASE	Galvanized steel	POLYESTER	≧1.5 mils
EXTERNAL FRONT PANEL	Galvanized steel	POLYESTER	≧1.5 mils
PILLAR	Galvanized steel	POLYESTER	≧1.5 mils
COMPRESSOR COVER	ASTM material	Resin Paint	≧0.78 mils
FIN GUARD	Iron wire	Resin Paint	≧0.79 mils
FAN GUARD AND DRUM	Polypropylene	No treatment required	N/A

FAN	Acrylonitrile - glass	No treatment required	N/A
FAN MOTOR FRAME	Resin	No treatment required	N/A
FAN MOTOR SHAFT	Carbon steel	No treatment required	N/A
FAN MOTOR SUPPORT	Galvanized steel	POLYESTER	≥1.5 mils
HEAT EXCHANGERS (FIN ONLY)	Aluminum	Polymer Anti-corrosion surface treatment	Salt Spray 1000 hours, blister rating 10
ELECTRICAL PARTS BOX	Hot-dip zinc-coated steel	No treatment required	N/A
ELECTRICAL PARTS BOARD	Glass cloth / Glass nonwoven cloth material	Insulation Varnish	No specific thickness
SCREWS	Carbon steel wire rods	High corrosion resistance treatment	≥0.28 mils

2.4 OUTDOOR/CONDENSING UNIT

A. GENERAL:

1. The condensing unit is designed specifically for use with VRV series components.
2. The condensing unit shall be factory assembled in the USA and pre-wired with all necessary electronic and refrigerant controls.
3. The refrigeration circuit of the condensing unit shall consist of Daikin inverter scroll compressors, motors, fans, condenser coil, electronic expansion valves, solenoid valves, 4-way valve, distribution headers, capillaries, filters, shut off valves, oil separators, service ports and refrigerant accumulator.
4. Liquid and suction lines must be individually insulated between the condensing and indoor units.
5. The condensing unit can be wired and piped with access from the left, right, rear or bottom.
6. The connection ratio of indoor units to condensing unit shall be permitted up to 200% of nominal capacity.
7. Each condensing system shall be able to support the connection of up to 64 indoor units dependent on the model of the condensing unit.
8. The sound pressure level standard shall be that value as listed in the Daikin engineering manual for the specified models at 3 feet from the front of the unit. The condensing unit shall be capable of operating automatically at further reduced noise during nighttime or via an external input.
9. The system will automatically restart operation after a power failure and will not cause any settings to be lost, thus eliminating the need for reprogramming.

10. The unit shall incorporate an auto-charging feature to ensure optimum performance. Manual changing should be support with a minimum of 2 hours of system operation data to ensure correct operation.
11. The condensing unit shall be modular in design and should allow for side-by-side installation with minimum spacing.
12. The following safety devices shall be included on the condensing unit; high pressure sensor and switch, low pressure switch, control circuit fuses, crankcase heaters, fusible plug, overload relay, inverter overload protector, thermal protectors for compressor and fan motors, over current protection for the inverter and anti-recycling timers.
13. To ensure the liquid refrigerant does not flash when supplying to the various indoor units, the circuit shall be provided with a sub-cooling feature.
14. Oil recovery cycle shall be automatic occurring 2 hours after start of operation and then every 8 hours of operation.
15. The condensing unit shall be capable of heating operation at 0°F (-18°C) dry bulb ambient temperature without additional low ambient controls or an auxiliary heat source.

B. UNIT CABINET:

1. The condensing unit shall be completely weatherproof and corrosion resistant. The unit shall be constructed from rust-proofed galvanized steel panels coated with a baked enamel finish.

C. FAN:

1. The condensing unit shall consist of one or more propeller type, direct-drive 500 or 600 W fan motors that have multiple speed operation via a DC (digitally commutating) inverter. Reference table below.

MODEL NUMBER	FAN MOTOR OUTPUT (W) & QUANTITY
RXYQ72TAYD*	500 x 1
RXYQ96TAYD*	600 x 2
RXYQ120TAYD*	600 x 2
RXYQ240TAYD*	600 x 2

2. The condensing unit fan motor shall have multiple speed operation of the DC (digitally commutating) inverter type, and be of high external static pressure and shall be factory set as standard at 0.12 in. WG. A field setting switch to a maximum 0.32 in. WG pressure is available to accommodate field applied duct for indoor mounting of condensing units.
3. The fan shall be a vertical discharge configuration with a nominal airflow maximum range of 5,544 CFM to 22,283 CFM dependent on model specified.
4. The fan motor shall have inherent protection and permanently lubricated bearings and be mounted.
5. The fan motor shall be provided with a fan guard to prevent contact with moving parts.

D. SOUND:

1. Nominal sound pressure levels shall be as shown below.

MODEL NUMBER	SOUND PRESSURE LEVEL dB(A)
RXYQ72TAYD*	58
RXYQ96TAYD*	61
RXYQ120TAYD*	61
RXYQ240TAYD*	61

2. Night setback control of the fan motor for low noise operation by way of automatically limiting the maximum speed shall be a standard feature. Operation sound level shall be selectable from 3 steps.

OPERATION SOUND dB(A)	NIGHT MODE SOUND PRESSURE LEVEL dB(A) APPROX.
Level 1	55
Level 2	50
Level 3	45

E. CONDENSER COIL:

1. The condenser coil shall be manufactured from copper tubes expanded into aluminum fins to form a mechanical bond.
2. The heat exchanger coil shall be of a waffle louver fin and rifled bore tube design to ensure high efficiency performance.
3. The heat exchanger on the condensing units shall be manufactured from Hi-X seamless copper tube with N-shape internal grooves mechanically bonded on to aluminum fins to an e-Pass Design.
4. The fins shall be coated with an anti-corrosion hydrophilic blue coating as standard from factory with a salt spray test rating of 1000hr per ASTM test standards.
5. The outdoor coil shall have three-circuit heat exchanger design eliminating the need for a drain pan heater. The lower part of the coil shall be used for inverter cooling and be on or off during heating operation enhancing the defrost operation.
 - a. An alternate manufacturer must provide a drain pan heater to enable adequate defrosting of the unit in defrost operation.
6. The condensing unit shall be factory equipped with condenser coil guards on all sides.

F. COMPRESSOR:

1. The Daikin inverter scroll compressors shall be variable speed (PVM inverter) controlled which is capable of changing the speed to follow the variations in total cooling and heating load as determined by the suction gas pressure as measured in the condensing unit.
 - a. In addition, samplings of evaporator and condenser temperatures shall be made so that the high/low pressures detected are read every 20 seconds and calculated. With

each reading, the compressor capacity (INV frequency) shall be controlled to eliminate deviation from target value.

- 1) Non –inverter-driven compressors, which may cause starting motor current to exceed the nominal motor current (RLA) and require larger wire sizing, shall not be allowed.
2. The inverter driven compressors in the condensing unit shall be of highly efficient reluctance DC (digitally commutating), hermetically sealed scroll “G-type” or “J-type.”
3. Neodymium magnets shall be adopted in the rotor construction to yield a higher torque and efficiency in the compressor instead of the normal ferrite magnet type.
 - a. At complete stop of the compressor, the neodymium magnets will position the rotor into the optimum position for a low torque start.
4. The capacity control range shall be as low as 10% to 100%.
5. The compressor’s motor shall have a cooling system using discharge gas, to avoid sudden changes in temperature resulting in significant stresses on winding and bearings.
6. Each compressor shall be equipped with a crankcase heater, high pressure safety switch, and internal thermal overload protector.
7. Oil separators shall be standard with the equipment together with an intelligent oil management system.
8. The compressor shall be spring mounted to avoid the transmission of vibration eliminating the standard need for spring insulation.
9. In the event of compressor failure, the remaining compressors shall continue to operate and provide heating or cooling as required at a proportionally reduced capacity. The microprocessor and associated controls shall be manually activated to specifically address this condition for single module and manifolded systems.
10. In the case of multiple condenser modules, conjoined operation hours of the compressors shall be balanced by means of the Duty Cycling Function, ensuring sequential starting of each module at each start/stop cycle, completion of oil return, completion of defrost or every 8 hours. When connected to a central control system sequential start is activated for all system on each DIII network.
11. Compressor configurations:

MODEL NUMBER	COMPRESSOR MOTOR OUTPUT (W)	QUANTITY	COMPRESSOR TYPES
RXYQ72TAYD*	3,400	1	Inverter controlled
RXYQ96TAYD*	4,100	1	Inverter controlled
RXYQ120TAYD*	5,200	1	Inverter controlled
RXYQ240TAYD*	5,200	2	Inverter controlled

2.05 FXMQ_PB - CONCEALED CEILING DUCTED UNIT (Med. Static)

A. General: Daikin indoor unit FXMQ_PB shall be a built-in ceiling concealed fan coil unit, operable with refrigerant R-410A, equipped with an electronic expansion valve, direct-drive DC (ECM) type fan with auto CFM adjustment at commissioning, for installation into the ceiling cavity. It is constructed of a galvanized steel casing. It shall be available in capacities from 7,500 Btu/h to 48,000 Btu/h. Model numbers are FXMQ07PBVJU, FXMQ09PBVJU, FXMQ12PBVJU, FXMQ15PBVJU, FXMQ18PBVJU, FXMQ24PBVJU, FXMQ30PBVJU, FXMQ36PBVJU, FXMQ48PBVJU, and FXMQ54PBVJU to be connected to outdoor unit model RXYQ / RXYMQ / RWEYQ heat pump and REYQ / RWEYQ heat recovery model. It shall be a horizontal discharge air with horizontal return air configuration. All models feature a low height cabinet making them applicable to ceiling pockets that tend to be shallow. Computerized PID control shall be used to control superheat to deliver a comfortable room temperature condition. The unit shall be equipped with a programmed drying mechanism that dehumidifies while limiting changes in room temperature when used with Daikin remote control BRC1E72, BRC1E73 and BRC2A71. Included as standard equipment, a condensate drain pan and drain pump kit that pumps to 18-3/8” from the drain pipe opening. The indoor units sound pressure shall range from 29 dB(A) to 43 dB(A) at low speed measured 5 feet below the ducted unit.

B. Performance: Each unit’s performance is based on nominal operating conditions:

Model Number	Cooling (Indoor 80°F DB / 67°F WB, Outdoor 95°F DB, 25 ft pipe length)	Heating (Indoor 70°F DB Outdoor 47F / 43F, 25 ft pipe length)
FXMQ24PBVJU	24,000	27,000

C. Indoor Unit:

1. The Daikin indoor unit FXMQ_PB shall be completely factory assembled and tested. Included in the unit is factory wiring, piping, electronic proportional expansion valve, control circuit board, fan motor thermal protector, flare connections, condensate drain pan, condensate drain pump, condensate safety shutoff and alarm, self-diagnostics, auto-restart function, 3-minute fused time delay, and test run switch. The unit shall be equipment with automatically adjusting external static pressure logic that is selectable during commissioning. This adjusts the airflow based on the installed external static pressure.
2. Indoor unit and refrigerant pipes will be charged with dehydrated air prior to shipment from the factory.
3. Both refrigerant lines shall be insulated from the outdoor unit.

4. The indoor units shall be equipped with a condensate pan and condensate pump. The condensate pump provides up to 18-3/8” of lift from the center of the drain outlet and has a built in safety shutoff and alarm.
5. The indoor units shall be equipped with a return air thermistor.
6. The indoor unit will be separately powered with 208~230V/1-phase/60Hz.
7. The voltage range will be 253 volts maximum and 187 volts minimum.

D. Unit Cabinet:

1. The cabinet shall be located into the ceiling and ducted to the supply and return openings.
2. The cabinet shall be constructed with sound absorbing foamed polystyrene and polyethylene insulation.

E. Fan:

1. The fan shall be direct-drive DC (ECM) type fan, statically and dynamically balanced impeller with three fan speeds available.
2. The unit shall be equipment with automatically adjusting external static pressure logic selectable during commissioning.
3. The fan motor shall operate on 208/230 volts, 1 phase, 60 hertz with a motor output range of 0.12 to 0.47 HP respectively.
4. The airflow rate shall be available in three settings.
5. The fan motor shall be thermally protected.
6. The fan motor shall be equipped as standard with adjustable external static pressure (ESP) settings.
7. Fan motor external static pressure range for nominal airflow:

Model Number	Fan ESP (in. WG)
FXMQ05PBVJU – FXMQ54PBVJU	0.80 – 0.20

Notes: Refer to Construction Drawings for characteristics and requirements.

F. Coil:

1. Coils shall be of the direct expansion type constructed from copper tubes expanded into aluminum fins to form a mechanical bond.
2. The coil shall be of a waffle louver fin and high heat exchange, rifled bore tube design to ensure highly efficient performance.
3. The coil shall be a 3 row cross fin copper evaporator coil with 15 fpi design completely factory tested.
4. The refrigerant connections shall be flare connections and the condensate will be 1-1/4” outside diameter PVC.
5. A condensate pan shall be located under the coil.
6. A condensate pump with an 18-3/8” lift shall be located below the coil in the condensate pan with a built in safety alarm.
7. A thermistor will be located on the liquid and gas line.

G. Electrical:

1. A separate power supply will be required of 208/230 volts, 1 phase, 60 hertz. The acceptable voltage range shall be 187 to 253 volts.
2. Transmission (control) wiring between the indoor and outdoor unit shall be a maximum of 3,280 feet (total 6,560 feet).
3. Transmission (control) wiring between the indoor unit and remote controller shall be a maximum distance of 1,640 feet.

H. Control:

1. The unit shall have controls provided by Daikin to perform input functions necessary to operate the system.
2. The unit shall be compatible with interfacing with a BMS system via optional LonWorks or BACnet gateways.
3. The unit shall be compatible with a Daikin Intelligent Touch Manager advanced multi-zone controller.

I. Optional Accessories Available:

1. Remote “in-room” sensor kit KRCS01-4B.
 - i. The Daikin wall mounted, hard wired remote sensor kit is recommended for when a NAV controller is not used or when the NAV controller is not located in the space that is being controlled. The sensor for detecting the temperature can be placed away from the indoor unit (branch wiring is included in the kit).
2. MERV 8 Filter kit. Can be configured for right or left access. Filters replaceable without tools.

2.06 FXAQ – WALL MOUNTED UNIT

- a. General: Daikin indoor unit FXAQ shall be a wall mounted fan coil unit, operable with refrigerant R-410A, equipped with an electronic expansion valve, for installation onto a wall within a conditioned space. This compact design with finished white casing shall be available in capacities from 7,500 Btu/h to 24,000 Btu/h. Model numbers are FXAQ07PVJU, FXAQ09PVJU, FXAQ12PVJU, FXAQ18PVJU and FXAQ24PVJU to be connected to outdoor unit model RXYQ / RXYMQ / RWEYQ heat pump and REYQ / RWEYQ heat recovery model. Computerized PID control shall be used to control superheat to deliver a comfortable room temperature condition. The unit shall be equipped with a programmed drying mechanism that dehumidifies while limiting changes in room temperature when used with Daikin remote control BRC1E72, BRC1E73 and BRC2A71. A mildew-proof, polystyrene condensate drain pan and resin net mold resistant filter shall be included as standard equipment. The indoor units sound pressure shall range from 31 dB(A) to 41 dB(A) at low speed measured at 3.3 feet below and from the unit.
- b. Performance: Each unit’s performance is based on nominal operating conditions:

Model Number	Cooling (Indoor 80°F DB / 67°F WB, Outdoor 95°F DB, 25 ft pipe length)	Heating (Indoor 70°F DB Outdoor 47F / 43F, 25 ft pipe length)
FXAQ07PVJU	7,500	8,500
FXAQ09PVJU	9,500	10,500
FXAQ12PVJU	12,000	13,500
FXAQ18PVJU	18,000	20,000
FXAQ24PVJU	24,000	26,500

c. Indoor Unit:

- i. The Daikin indoor unit FXAQ shall be completely factory assembled and tested. Included in the unit is factory wiring, piping, electronic proportional expansion valve, control circuit board, fan motor thermal protector, flare connections, condensate drain pan, self-diagnostics, auto-restart function, 3-minute fused time delay, and test run switch. The unit shall have an auto-swing louver which ensures efficient air distribution, which closes automatically when the unit stops. The remote controller shall be able to set five (5) steps of discharge angle. The front grille shall be easily removed for washing. The discharge angle shall automatically set at the same angle as the previous operation upon restart. The drain pipe can be fitted to from either left or right sides.
- ii. Indoor unit and refrigerant pipes will be charged with dehydrated air prior to shipment from the factory.
- iii. Both refrigerant lines shall be insulated from the outdoor unit.
- iv. Return air shall be through a resin net mold resistant filter.
- v. The indoor units shall be equipped with a condensate pan.
- vi. The indoor units shall be equipped with a return air thermistor.
- vii. The indoor unit will be separately powered with 208~230V/1-phase/60Hz.
- viii. The voltage range will be 253 volts maximum and 187 volts minimum.

d. Unit Cabinet:

- i. The cabinet shall be affixed to a factory supplied wall mounting template and located in the conditioned space.
- ii. The cabinet shall be constructed with sound absorbing foamed polystyrene and polyethylene insulation.

e. Fan:

- i. The fan shall be a direct-drive cross-flow fan, statically and dynamically balanced impeller with high and low fan speeds available.
- ii. The fan motor shall operate on 208/230 volts, 1 phase, 60 hertz with a motor output range 0.054 to 0.058 HP.
- iii. The airflow rate shall be available in high and low settings.
- iv. The fan motor shall be thermally protected.

f. Coil:

- i. Coils shall be of the direct expansion type constructed from copper tubes expanded into aluminum fins to form a mechanical bond.
- ii. The coil shall be of a waffle louver fin and high heat exchange, rifled bore tube design to ensure highly efficient performance.
- iii. The coil shall be a 2-row cross fin copper evaporator coil with 14 fpi design completely factory tested.
- iv. The refrigerant connections shall be flare connections and the condensate will be 11/16 inch outside diameter PVC.
- v. A thermistor will be located on the liquid and gas line.
- vi. A condensate pan shall be located in the unit.

g. Electrical:

- i. A separate power supply will be required of 208/230 volts, 1 phase, 60 hertz. The acceptable voltage range shall be 187 to 253 volts.
- ii. Transmission (control) wiring between the indoor and outdoor unit shall be a maximum of 3,280 feet (total 6,560 feet).
- iii. Transmission (control) wiring between the indoor unit and remote controller shall be a maximum distance of 1,640 feet.

h. Control:

- i. The unit shall have controls provided by Daikin to perform input functions necessary to operate the system.
- ii. The unit shall be compatible with interfacing with a BMS system via optional LonWorks or BACnet gateways.
- iii. The unit shall be compatible with a Daikin Intelligent Touch Manager advanced multi-zone controller.

i. Optional Accessories:

- i. Remote “in-room” sensor kit KRCS01-1B.
- ii. A condensate pump (DACA-CP3-1)

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine areas and conditions for compliance with requirements for installation tolerances and other conditions affecting performance of water-source heat pumps.

- B. Examine roughing-in for piping and electric installations for water-source heat pumps to verify actual locations of piping connections and electrical conduit before installation.
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION

- A. Concrete Bases: Install floor mounting units on 4-inch- high concrete bases. See Division 23 Section "Basic Mechanical Materials and Methods" for concrete base materials and fabrication requirements.
- B. Mount heat pumps on concrete base with vibration isolators and seismic restraints as required by Division 23 Section "Vibration and Seismic Controls for HVAC Piping and Equipment."
- C. Suspend heat pumps from structure with threaded steel rods and spring vibration isolators and seismic restraints as required by Division 23 Section " Vibration and Seismic Controls for HVAC Piping and Equipment."
- D. Install wall-mounting thermostats, humidistats, and switch controls in electrical outlet boxes at heights to match lighting controls or as required in Division 23 Section "HVAC Instrumentation and Controls."

3.3 CONNECTIONS

- A. Drawings indicate general arrangement of piping, fittings, and specialties. Specific connection requirements are as follows:
 - 1. Connect supply and return hydronic piping to heat pump with hose kits.
 - 2. Connect heat-pump condensate drain pan to indirect waste connection with condensate trap of adequate depth to seal against the pressure of fan. Install cleanouts in piping at changes of direction.
- B. Duct installation requirements are specified in other Division 23 Sections. Drawings indicate general arrangement of ducts. Specific connection requirements are as follows:
 - 1. Connect supply and return ducts to water-source heat pumps with flexible duct connectors specified in Division 23 Section "Duct Accessories."
 - 2. Install ducts to termination in roof curb.
 - 3. Remove roof decking only as required for passage of ducts. Do not cut out decking under entire roof curb.
 - 4. Terminate return-air duct through roof structure and insulate space between roof and bottom of unit with 2-inch- thick, acoustic duct liner.
 - 5. Install normal-weight, 3000 psi, compressive-strength (28-day) concrete mix inside roof curb, 4 inches thick. Concrete, formwork, and reinforcement are specified in Division 3.
- C. Install electrical devices furnished by manufacturer but not specified to be factory mounted.
- D. Install piping adjacent to machine to allow service and maintenance. Note: Do not anchor piping in any way to the heat pump itself.

- E. Ground equipment according to Division 26 Section "Grounding and Bonding for Electrical Systems."
- F. Connect wiring according to Division 26 Section "Low-Voltage Electrical Power Conductors and Cables."

3.4 FIELD QUALITY CONTROL

- A. **Manufacturer's Field Service:** Engage a factory-authorized service representative to inspect, test, and adjust field-assembled components and equipment installation, including connections. Report results in writing.
- B. Perform the following field tests and inspections and prepare test reports:
 - 1. After installing water-source heat pumps and after electrical circuitry has been energized, test units for compliance with requirements.
 - 2. Inspect for and remove shipping bolts, blocks, and tie-down straps.
 - 3. **Operational Test:** After electrical circuitry has been energized, start units to confirm proper motor rotation and unit operation.
 - 4. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and equipment.
- C. Remove and replace malfunctioning units and retest as specified above.

3.5 STARTUP SERVICE

- A. Engage a factory-authorized service representative to perform startup service.
- B. Complete installation and startup checks according to manufacturer's written instructions and do the following:
 - 1. Inspect for visible damage to unit casing.
 - 2. Inspect for visible damage to compressor, coils, and fans.
 - 3. Inspect internal insulation.
 - 4. Verify that labels are clearly visible.
 - 5. Verify that clearances have been provided for servicing.
 - 6. Verify that controls are connected and operable.
 - 7. Verify that filters are installed.
 - 8. Adjust vibration isolators.
 - 9. Inspect operation of barometric dampers.
 - 10. Verify bearing lubrication on fan.
 - 11. Inspect fan-wheel rotation for movement in correct direction without vibration and binding.
 - 12. Adjust fan belts to proper alignment and tension.
 - 13. Start unit according to manufacturer's written instructions.
 - 14. Complete startup sheets and attach copy with Contractor's startup report.
 - 15. Inspect and record performance of interlocks and protective devices; verify sequences.
 - 16. Operate unit for an initial period as recommended or required by manufacturer.
 - 17. Verify thermostat and humidistat calibration.

18. Inspect outdoor-air dampers for proper stroke and interlock with return-air dampers.
19. Inspect controls for correct sequencing of heating, mixing dampers, refrigeration, and normal and emergency shutdown.

3.6 ADJUSTING

- A. Adjust initial temperature and humidity set points.
- B. Set field-adjustable switches and circuit-breaker trip ranges as indicated.
- C. Occupancy Adjustments: When requested within 12 months of date of Substantial Completion, provide on-site assistance in adjusting system to suit actual occupied conditions. Provide up to two Insert number visits to Project during other than normal occupancy hours for this purpose.

3.7 CLEANING

- A. Replace filters used during construction prior to air balance or substantial completion.
- B. After completing installation of exposed, factory-finished water-source heat pumps, inspect exposed finishes and repair damaged finishes.

3.8 DEMONSTRATION

- A. Engage a factory-authorized service representative to train Owner's maintenance personnel to adjust, operate, and maintain water-source heat pumps. Refer to Division 01 Section "Demonstration and Training." Training shall be included for a total of 4 hours; (2) 2-hour sessions.

END OF SECTION 238129